


SICHERHEITSINFORMATIONEN

SAFETY INFORMATION

DE	Sicherheitsinformationen	HU	Biztonsági információk	LT	Saugos informacija
EN	Safety information	RU	Информация о безопасности	LV	Drošības informācija
FR	Informations sur la sécurité	TR	Güvenlik bilgileri	HR	Sigurnosne informacije
NL	Veiligheidsinformatie	FI	Turvallisuustiedot	RO	Informații privind siguranța
IT	Informazioni sulla sicurezza	GR	Πληροφορίες για την ασφάλεια	BG	Информация за безопасност
SE	Säkerhetsinformation	PT	Informações de segurança	DK	Oplysninger om sikkerhed
ES	Información de seguridad	EE	Ohutusalane teave	NO	Sikkerhetsinformasjon
PL	Informacje dotyczące bezpieczeństwa	SK	Bezpečnostné informácie	UA	Інформація з техніки безпеки
CZ	Bezpečnostní informace	SI	Varnostne informacije	AR	معلومات السلامة

WWW.BRENNENSTUHL.COM

11/12/2025



**brennenstuhl® WiFi Smoke detector
RM A 3020**

WARNING: 1: Only use battery specified in manual. 2: Replace battery when unit chirps with the red LED flashing once every 48 seconds. 3: Constant exposure to high or low temperatures may reduce the battery life. 4: Test weekly, clean by vacuuming the outside of the unit each month. For further information, refer to the user's manual. 5: Test the alarm is working correctly by using the test button whenever the battery is replaced. 6: Read the manual before using or servicing.

Recommended battery: Raymax LR6, Pairdeer LR6
Brennenstuhl UK Ltd · No 1 Royal Exchange · London EC3V 3DG, UK

Intended use:
Fire protection

Wireless Frequency: 2.4 GHz
Battery Spec:
DC 2 x 1.5 V alkaline AA battery
Art. no.: 1290090010
Date of production: 2025.11
Date of replacement: 2035.11

connect
brennenstuhl®
WiFi
Hugo Brennenstuhl GmbH & Co. KG
Seestr. 1-3, D-72074 Tübingen
service@brennenstuhl.com
0529385/2325

CE 25
1116-CPR-190-2
DOP-BRT-0016
EN 14604:2005/AC:2008



4 007123 688951
4915 4525 **EN**

33.00 mm

78.00 mm

